

## SOUTH METRO FIRE DEPARTMENT

**Fire Prevention Division** 

1650 Humboldt Avenue • West St. Paul MN 55118 Phone: (651) 552-4172 • FAX: (651) 552-4195 www.smfdmn.org

## Above Ground Storage Tank Installation Permit Application

| Application Date:  | Permit Fee \$66.50   |
|--|----------------------|
| Site Information   |                      |
| Site Name:   |                      |
| Owners Name:   |                      |
| Address:   |                      |
| Phone:   | E-Mail:              |
| Contractor Information   |                      |
| Name:  |                      |
| Address:   |                      |
| Contact Name:  |                      |
| Phone:   | E-Mail:              |
| State License Number:  | MPCA License Number: |
| Project Information  |                      |
| Estimated Date of Completion:  |                      |
| Project Description:   |                      |
|  |                      |
|  |                      |
|  |                      |
|  |                      |
| The undersigned hereby agrees to do all the work in accordance with the Local Jurisdiction,<br>MPCA, MN State Building Code, MN State Fire Code, NFPA 30, to all recognized standards, and |                      |
| the conditions listed on the backside of this Permit application form.   |                      |
| Signature:   | Date:                |
|  |                      |

Click submit form to send or print and email to tjohnson@southmetrofire.com.

## CONDITIONS AND ADDITIONAL REQUIREMENTS FOR INSTALLATION OF ABOVEGROUND STORAGE TANK

- > Plans/drawings shall be submitted to the fire department with the application.
- Submittal shall include:
  - Plans and drawings to scale, including measurements to buildings, roads and the public way.
  - Manufactures spec/cut sheets and literature on the tank(s) and all components.
  - Provide a copy of MPCA state contractor's license.
- > Provide emergency shut-off in accordance with the MSFC and NFPA.
- > Provide appropriate signage in accordance with MSFC and NFPA.
- Guard posts or other approved means shall be provided to protect tanks, piping, valves or fittings subject to vehicular damage.
- Spill control, drainage control and diking shall be in accordance with the MSFC section 3404.2.10,
- > A portable fire extinguisher with a minimum rating of 20-BC shall be provided.
- Obtain a city mechanical permit.

Fire department personnel shall be present during acceptance test procedures in accordance with the requirement in MSFC and NFPA 30. Call 651-552-4172 at least 48 hours in advance to schedule an appointment.